

We have the **energy** to make things work ... for you.

Getting to know PSE&G



- 6th Highest Gas Utility in US sales
- Serves 10 of the top 15 cities in NJ
- ~2,400 employees
- 12 District Headquarters
- 17,955 miles of gas distribution main
- 57 miles of gas transmission main
- 1.2 million gas services
- 1.8 million gas customers
- Sales volume growth: 1% per year

What is the Gas System Modernization Program (GSMP)?

- Accelerated cast iron and unprotected steel main and service replacement program
- Upgrades legacy low (utilization) pressure systems to medium pressure
- Relocates inside meter sets to outside
- Installs excess flow valve (EFV) safety devices
- Supports DOT focus on replacing the highest risk, most leak prone facilities



Continued replacement at these levels would replace/rehabilitate all the cast iron and unprotected steel by 2040



Gas System Modernization Program

- PSE&G currently operates and maintains over 3,900 miles of cast iron and unprotected steel gas distribution main.
- The program provides for investment and clause recovery of Utilization Pressure Cast Iron (UPCI) and Unprotected Steel replacement main, services, and associated uprating of plastic and protected steel in targeted areas
 - GSMP I started in 2016 (3 year term \$900M)
 - GSMP II started in 2019 (5 year term \$1.9B)
- Stipulated Base CapEx spend requirement associated with the program approval
 - Includes High Pressure Cast Iron (HPCI), UPCI, unprotected steel main and service replacement
 - Includes program and stipulated base inside meter set relocations
- Total ~170 miles of main replacement per year in Program and Stipulated Base
- The first two approvals are the beginning phases of a long-term 25 year replacement strategy for cast iron and unprotected steel mains
- Benefits:
 - Methane emission reduction is estimated at 30,000 metric tons of CO2 equivalent per year*
 - Medium pressure system allows usage of high efficiency appliances by customers
 - Includes installation of excess flow valve safety devices where applicable

GSMP Stipulation

The replacement of mains in the Program shall follow the prioritization based on the grid based Leak Hazard Indices developed by PSE&G using its Hazard Assessment model.

"...Recognizing that considering methane emission flow volume (i.e., emission size) as part of prioritization will reduce the amount of natural gas lost from emissions to the benefit of customers, and reduce the environmental impacts of such emissions, the Signatories agree that for grids with comparable Hazard Index/Mile, available methane emissions survey data estimating flow volumes, as prepared by the Environmental Defense Fund using Program plans, system information and maps provided by PSE&G, will be used, as appropriate, in sub-prioritizing replacement activities..."



Accelerated UP Cast Iron (UPCI) Replacement

- Goal Replace priority areas most efficiently
 - Highest potential hazard
 - Contiguous area for construction efficiency
- Map grid system utilized
 - 1 square mile area
 - 1 20 miles of low pressure cast iron per grid
 - Similar environmental conditions





PSE&G Grid Mapping System

3¢-13N3A-13N2Z-13N 3B-13N 3C-12N3A-12N2Z-12N 3B-12N 3D-11N 3E-11N 3C-11N3A-11N2Z-11N 2V-11N 2T-11N ðB-11N 2Y-11N 2U-11N 3D-10N 3E-10N 30-10N3A-10N2Z-10N 2V-10N 2T-10 3B-10N 2Y-10N 7 2U-10N <u>30-09</u> 2R-09N 3D-09 27-09 2P-09N2N-09N 3G -09N 3F -09N 3E 409N 3A-09N2Z-09N 2V-09N 3B-09N 2Y-09N 2U-09N 2R-08N 8D-08N 3C-08 3G -08N 3F -08N 3E -08N 2V-08N 2P_08N2N-08N 3A-08N2Z-08N 2T-08 2Y-08N/ 2U-08N 3B-08N 2S-08N 3G -07N 3D-07N3C-07I 2R-07 2P-07N 3U-07N 3F-07N3E-07N 2V-07N 2T-07N 21-07N 20-07N 2H-07N 3A-07N2Z-07N 2Y-07N 2U-07N 2S-07N 3H-3B-07N 2N-07N 2K-07N 3D-06N 3C-06 ZK-06 2Þ 2J-06N2H-06N 3F -06N 3E -06N 3A-06N2Z-06N 2V-06N 21-06 2L-06N 2YF-06N 2U-06N 2S-06N 2N-06N 2K-06N ×., ¥3H-06N 3B--06N 2G-05N 2D-05N 2C-05N 3D-05N 3C-05 3A-05N 2Z-05N 30/050 05N 2L-05N 2J-05N 2F_05N2E-05N 2B-05N 3F-05N3E-05N 2V-05N 2T-05N -05N 3K-05N 3H-05N 2Y-05N 2U-05N 2N-05N 2K-05N 3B-05N 2S-05 2H-05N 3D-04N 3C-04 20-94N 2C-04N -04M 3U-04M 2P-04N -04N 2E -04N 2B-04N 3F-04N3E-04N 2L-04N 2J-04 3A-04N 2Z-04N 2V-04N 2T-04 2N 04N 2K-04N 2H-04N 2X 04N 120504N 3K-04N 3H-04N 3B -04N 25 2D-03N 2C-03N 2R-03 3D-03N 3C-03 20-03N 2T-03N 2A=03N 1Z-03N 1V-03N -031 31-031 3F-03N3E-03N 2R-03N 2L-03N 2U-03N 42F-03N2E-03N 3A-03N 22-03N 3H-03N 2Y-03N -2U-03N 2N-03N -03N 2H-03N 2B-03N 1Y-03N 3K-03N 3B 29-03N 3D-02N 3C-02N 2R-02N 2D-02M -02N2E-02N 2A-02N 1Z-02N 11/-021 35-02N 3E-02N 2P-02N 2L-02N 3A-02N2Z-02N C2V-02N 2T-02N -02N 3J-02 25-02N 2Y-02N 2U-02N 2B-02N 1Y-02N 2N 02N 2K 02N 2H 02N 3K-02N * 3B-02N 3H-02M 1R-01N 3D-01N 3C-0 ZR-01 2D-01N2C 36-01N3F-01N3E-01N 2P-01N -01N 2E-01N ZA-01N1Z-01N 1V-01N 1T-01N 1S-01N 2V-01N 3A-01N 2Z-01N 2L-01N 21-01 2R-01N 21-01N 2B-01N 2U-01N 2S-01N 2N-01N ^F1Y-01N 10-01N 3B-01N 2Y-01Ň 5 2D-602 IT 6015-601R-60 3B-603A-602Z 2T-602S-60 60 ZE -60 /2P-60 2B-602A-601Z 36-603F-603E-60 2J-602H PV-60 21 10.00 - 21 × Ř-60 2N-60 2K-60 1Y-60 C-60 2G 2D-59 - 8 2F 2B 592A-591Z 59 IT-5915-591R -59 3C-593B-593A-\$92Z F-592S-5 592E-50 2V-59 2P-59 2J-502H -59 50 2N-59 2G 2R-59 2K-59 3D-59 1T-581S-581R-58 2L-58 2A-58 Z-58 V-58 {2J-682H -5826-58 E-58 3C-583B-583A-582Z-58 2V-58 -582S-58 2P-58 2F 3D-58 20-5 2R-58 2N-58 2K-68 20-572C-57 I€571S-57 2F-572E-57 R-57 28-572A-571Z-57 V 57 -3C-073B-573A-572Z-57 21-5728-57 -57 2V-57 2P-57 -57 2J-572 2R-57 2G 57 1 57 3D 🐴 7 20 57 2N-5 2K 2D-562C 434661S-5 1R-56 2F-562E-56 8E-56 3C 563B-563A-562Z-5 21-5628-56 2P-56 2J-562H-56 2B-56 2E-56°S 2N-56 1Y-56 56 1 2G-56 3D-56 2R-56 Ζ -552B-55 2B-552A-551Z-55 N-55 T-651S 551R-55 2P-55 2V-55 2T-552S-55 3A-552Z-55 2F 10 2U



Prioritization of UPCI Replacement Main

- Hazard Index (HI) rankings used to express and compare relative hazard for main segments having a history of breaks.
- Factors used in the calculation
 - Hazard Index = Weighted Break History (WBH) x Environmental Index (E)
 - WBH = The sum of the factors multiplied by the number of annual break repairs for each period (factors higher for recent breaks)
 - Environmental Index evaluates the environmental conditions at the main segment location that may affect the relative hazard of a break and is based upon the following factors
 - Building Density
 - Operating Pressure
 - Building Occupancy
 - Underground Utility
 - Building Set-back
 - Nominal Pipe Size
- Mileage is based upon total low pressure cast iron mileage in grid









Prioritization of UPCI Replacement Main (cont'd)

- Mains with break history Hazard Index
- Individual segments within a grid are summed to obtain total hazard index for the grid
- Miles of UPCI main in grid are summed
- Hazard score divided by miles gives HI/Mi score
- Map Grids ranked by HI/Mi



GSMP I - UP Cast Iron Main Prioritization



PSEG







Hazard Index – Grid 2L - 57

District	Street	Municipality	Install Year	Main Size	Main Type	Pressure	Segment Length	В	Ρ	o	υ	s	Last Repair Date	Number of Breaks	WВН	BPOU/S	Env Index E	Hazard Index	Wall Map Grid
DGOK	VINE ST	Haledon Boro	1900	6	CI	UP	700	4	1	4	2	1.5	1/8/2014	3	12	21	2.3012	27.615	2L-57
DGOK	DE ROON AVE	Haledon Boro	1900	4	CI	UP	458	8	1	4	3	1	4/4/2012	3	9	96	3.0307	27.2765	2L-57
DGOK	MORNINGSIDE AVE	North Haledon Boro	1953	4	CI	UP	929	8	1	4	3	1	1/28/2013	2	8	96	3.0307	24.2458	2L-57
DGOK	BELMONT AVE	North Haledon Boro	1927	8	CI	UP	460	8	1	15	4	1	11/6/2013	1	5	480	4.5596	22.7982	2L-57
DGOK	DE GRAY ST	Haledon Boro	1955	6	CI	UP	1037	4	1	4	3	1.5	2/14/2013	2	7	32	2.5705	17.9933	2L-57
DGOK	DAWN AVE	Haledon Boro	1951	6	CI	UP	426	8	1	4	3	1	1/14/2011	1	3	96	3.3	9.8999	2L-57
DGOK	GIONTI PL	North Haledon Boro	1928	6	CI	UP	885	4	1	4	2	3	2/11/2014	1	5	11	1.841	9.205	2L-57
DGOK	SQUAW BROOK RD	North Haledon Boro	1937	6	CI	UP	962	4	1	4	3	1	1/12/2009	2	2	48	2.8397	5.6794	2L-57
DGOK	MEADOW PL	North Haledon Boro	1954	4	CI	UP	187	4	1	4	4	1	2/22/2010	1	2	64	2.7615	5.523	2L-57
DGOK	DOROTHY DR	North Haledon Boro	1964	4	CI	UP	276	4	1	4	3	1	3/25/1999	2	2	48	2.5705	5.141	2L-57
DGOK	HIGH MOUNTAIN RD	North Haledon Boro	1900	8	CI	UP	109	2	1	4	3	1.5	12/30/2010	1	2	16	2.3012	4.6025	2L-57
DGOK	SUTER LN	North Haledon Boro	1954	4	CI	UP	93	4	1	4	1	1.5	2/20/2010	1	2	11	1.5718	3.1435	2L-57
DGOK	DAWN AVE	North Haledon Boro	1951	6	CI	UP	267	4	1	4	3	1	12/8/2003	1	1	48	2.8397	2.8397	2L-57
DGOK	DOROTHY DR	North Haledon Boro	1957	6	CI	UP	682	2	1	4	2	3	1/8/2001	2	2	5	1.3807	2.7615	2L-57
DGOK	VENNA AVE	Haledon Boro	1929	6	CI	UP	325	2	1	4	2	3	2/2/2009	1	1	5	1.3807	1.3807	2L-57
													_	Tot	al Haz	ard Score		170.1051	
														Total	CI Mile	es in Grid		3.75	
													Hazard Index Per Mile		45.36				



Top 20 Hazard Index/Mile

UPCI	UPCI	2014		
<u>GRID</u>	MILES	HAZARD INDEX	HAZARD INDEX/MILE	HI/MILE RANK
2A-48	1.0	55.0970	54.9	1
2L-57	3.7	170.2419	45.4	2
2K-45	5.0	185.4933	37.3	3
2Z-41	1.2	43.9937	37.2	4
2K-44	3.0	109.7977	36.7	5
2B-46	2.9	103.7972	36.2	6
2K-55	11.1	360.4543	32.5	7
2J-51	10.1	294.1113	29.1	8
2D-58	3.1	87.5603	28.2	9
2A-45	2.4	66.1032	28.0	10
2K-57	4.1	115.1842	27.9	11
2L-58	1.7	48.0314	27.7	12
3D-46	2.1	55.6910	26.6	13
3J-50	1.4	37.6969	26.0	14
1Z-47	7.7	200.3936	25.9	15
3C-25	1.4	35.9431	25.6	16
2H-50	6.6	162.3633	24.8	17
2L-51	8.1	194.9827	24.2	18
2H-45	3.6	87.6968	24.2	19
2L-43	7.1	167.2065	23.6	20



Methane as a Greenhouse Gas

- Methane has 84 times the warming effect of carbon dioxide over a 20 year period
- EDF estimates that about 25% of the manmade global warming we're experiencing today is caused by methane emissions



Typical Composition of Natural Gas

Methane	CH ₄	70-90%		
Ethane	C ₂ H ₆			
Propane	C ₃ H ₈	0-20%		
Butane	C ₄ H ₁₀			
Carbon Dioxide	CO ₂	0-8%		
Oxygen	0 ₂	0-0.2%		
Nitrogen	N ₂	0-5%		
Hydrogen sulphide	H ₂ S	0-5%		
Rare gases	A, He, Ne, Xe	trace		





Working with the EDF

- In advance of GSMP I, PSE&G engaged the Environmental Defense Fund (EDF) to quantify methane emissions in our service territory to consider in the prioritization of the work
- Mapping was performed over a six month period
- Study was done at no cost to PSE&G
- PSE&G followed the EDF equipment with its own optical methane leakmobile to compare data





Finding the ways that work

EDF Overview - Continued

- The EDF partnered with Google and Colorado State University on a nationwide program to detect and map methane leaks from natural gas distribution systems
- A Google street-view car, equipped with state of the art methane and meteorological sensors, was driven repeatedly along streets with natural gas pipelines to map emissions
- Urban areas have been mapped across the country (Birmingham, Boston, Burlington, Chicago, Dallas, Indianapolis, Jacksonville, Los Angeles, Mesa, Pittsburgh, Staten Island, and Syracuse)
- The same technology used to map these cities was also used for the PSE&G project







What Technology Was Used?

- Advanced GPS technology and anemometer
- Open path, Cavity Ring-Down Spectroscopy (CRDS)
 LiCor analyzer
- High data collection rate
- No pumps (closed path CRDS)
- The longer the laser path, the better the sensitivity in detecting molecular signatures
- Equipment uses a series of mirrors within the sample cavity to reflect the laser path from a distance of 25 cm to over 20 km



Methane Quantification Data



Fig 1. Ring Down Graph. Adapted from Picarro. Retrieved from Picarro.com

- Different gases absorb light (laser) at specific rates
- Normal atmospheric air has a certain decay pattern as the laser fades inside the sample chamber (blue graph)
- When a gas like methane is in the sample, it absorbs light at a different decay rate than the control (green graph)
- The laser wavelength and difference in decay rates is used to quantify methane by analyzing the sample data stream through a series of algorithms
- Wind and precipitation are factors in sampling

Readings vs Indications





Using the Results in GSMP I

- Hazard Index per Mile (HI/Mi) still primary risk ranking tool
- Any grid with HI/Mi > 25 is highest priority
- Where HI/Mi is comparable (< 25), EDF data used to help **sub-prioritize** by leak rate of liters per minute per mile of UPCI pipe in the grid (L/Min/Mi)
 - Grids with outlying leak rates of >10 L/Min/Mi take highest priority
 - Grids with leak rates of <10 L/Min/Mi as well as non-surveyed grids take secondary priority
- Grids are evaluated for construction efficiencies and logistics as well as permitting and municipality conflicts prior to setting the final prioritization
- Results reviewed with EDF and submitted to the NJ Board of Public Utilities



Reduction in Emissions

- Outlier grids (>10 L/min/mi) were looked to be moved up in schedule where possible
- Mains retired earlier than originally planned stop emitting methane faster
- By accelerating high emissions grids, PSE&G was able to reduce total grid emissions by 83% early in the program.
- To achieve the same emissions reductions, 35% less main abandonments were needed vs if PSE&G followed strictly by hazard ranking.
- The accelerated grids the company prioritized for upgrades accounted for more than 37% of the emissions but only 9% of the mileage on which leak rates were measured.





Continuing the Program into GSMP II

- GSMP II filed in 2017 and approved in Spring 2018 as a five year extension
- Hazard Index and methane mapping to be used again to prioritize grids
- Picarro was chosen to map 44 "B Grids" of similar HI/mi that covered the 280 miles agreed to in the stipulation





Reduction in Risk and Methane Mapping



Continuing to address the highest hazard main segments



Methane Quantification Survey

- Areas require 3 passes on each side of the street for proper sampling (95% statistical confidence interval)
- Indications are run through an algorithm with wind, vehicle speed, ethane content and other factors, leak rates are determined
- Heat maps can show areas of high emissions and calculated leak rates





Using GSMP II Results



- Discussion with EDF after data collected to set prioritization
- Threshold of 4.5 L/min/mi used for accelerating grids that were surveyed (down from 10 L/min/mi in GSMP I)
- 6 grids accelerated
- If retired sooner than "as is" plan, they account for 41% of the methane loss in only 16% of the grids surveyed
- Construction beginning in Spring of 2019



Key Takeaways



- Hazard Ranking and safety are highest priority
 - Hazard Rank and Leak Volume do not necessarily correlate
- Methane Emissions sub prioritization useful for areas of relatively equal hazard
 - Better for the environment
 - Less chance of non-hazardous leaks
 getting worse
 - Fewer potential customer calls/complaints
- Other LDC's and PUC's continue to discuss best applications for the technology's use







